## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer:	BOGE	,						
	Model Numbe	r: <b>S 110-</b>	4LF N		Date:	24.11.2021			
2	X Air-co	ooled	Water-cooled		Type:	Screw			
			-		# of Stages:	1			
3*	Full Load Operating Pressure			110	psig				
4	Drive Motor Nominal Rating			150		hp			
5	Drive Motor Nominal Efficiency			95	percent				
6	Fan Motor Nominal Rating (if applicable)			4,0	hp				
7	Fan Motor Nominal Efficiency			87,7	percent				
	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	128,9			679,4	18,97				
8*	102,4			556,8	1	18,38			
	77,1			426,9	1	18,06			
	52,5			282,8	18,57				
	41,2		204,8	20,12					
9*	Total Package Input Power at Zero Flow c, d			0,0		kW			
10	Isentropic Efficiency			75,8%	%				
11	15,00   35,00   30,00   25,000,075,000,025,050,075,000,025,0								

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <a href="www.cagi.org">www.cagi.org</a>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
   ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1