### **COMPRESSOR DATA SHEET**

# In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

## **Rotary Compressor: Variable Frequency Drive**

#### MODEL DATA - FOR COMPRESSED AIR

	Model Number: S 46-4 LF N   X Air-cooled   Water-cooled			Date:	29.11.2022
2			Type:		Screw
				# of Stages:	1
3*	Full Load Operating Pressur	perating Pressure <sup>b</sup> 125		psig <sup>b</sup>	
4	Drive Motor Nominal Rating		60	hp	
5	Drive Motor Nominal Efficiency		96	percent	
6	Fan Motor Nominal Rating (if applicable)		3,5	hp	
7	Fan Motor Nominal Efficier	су	89,5	percent	
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>	
	52,8		279,2	18,	
8*	44,5		223,2	19,95	
	36,6		177,3	20,65	
	29,3		129,6	22,58	
	21,9		83,7	26,12	
9*	Total Package Input Power	at Zero Flow <sup>c, d</sup>	0,0	kW	
10	Isentropic Efficiency		72,7%	%	
	35,00				
	30,00 30,00 25,00 20,00 15,00				
11					

#### 0,0 25,0 50,0 75,0 100,0 125,0 150,0 175,0 200,0 225,0 250,0 275,0 300

#### Capacity (ACFM)

Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator

Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
  - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	$\underline{ft^3} / \underline{min}$	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.