Rotary Compressor: Fixed Speed								
MODEL DATA - FOR COMPRESSED AIR								
1	Manufacturer: BOGE Compressor							
	Model Number: S 56-4 N	Date:	19.08.2022					
2	X Air-cooled Water-cooled	Type:	Screw					
		# of Stages:	1					
3*	Rated Capacity at Full Load Operating Pressure a, e	289	acfm ^{a,e}					
4*	Full Load Operating Pressure ^b	110	psig ^b					
5	Maximum Full Flow Operating Pressure ^c	125	psig ^c					
6	Drive Motor Nominal Rating	75	hp					
7	Drive Motor Nominal Efficiency	95,8	percent					
8	Fan Motor Nominal Rating (if applicable)	3	hp					
9	Fan Motor Nominal Efficiency	89,5	percent					
10*	Total Package Input Power at Zero Flow ^e	12,07	kW ^e					
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	49,72	kW^d					
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e	17,20	kW/100 cfm ^e					
13	Isentropic Efficiency	81,44	Percent					

Consult CAGI website for a list of participants in the third party verification program:

	ISO 1217 Anney C. ACEM						
		l is actual cubic feet per minute at inlet cond					
	 b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet. c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power. d. Total package input power at other than reported operating points will vary with control strategy. e. Tolerance is specified in ISO 1217, Annex C, as shown in table below: 						
	•						
Compressed Air & Gas Institute	NOTE: The terms "power" and "energy" are synonymous for purposes of this document.						
		Volume Flow Rate		Specific Energy	No Load / Zero Flow		
		at specified conditions	Volume Flow Rate	Consumption	Power		
Member	$\underline{m}^3 / \underline{min}$	<u>ft³ / min</u>	%	%	%		
	Below 0.5	Below 17.6	+/- 7	+/- 8			
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%		
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 1070		
ROT 030.1	Above 15	Above 529.7	+/- 4	+/- 5			
12/19 Rev 3 This form was develop	ed by the Compressed Air and Gas	Institute for the use of its members participatin	g in the PVP. CAGI has not independently	verified the reported data.			