| COMPRESSOR DATA SHEET<br>In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors |   |              |                         |  |  |  |  |
|--|---|--------------|-------------------------|--|--|--|--|
|  | Rotary Compressor: Fixed Speed<br>MODEL DATA - FOR COMPRESSED AIR                         |              |                         |  |  |  |  |
| 1  | Manufacturer: BOGE Compressor   |              |                         |  |  |  |  |
|  | Model Number: C 12-2 N  | Date:        | 08.10.2024              |  |  |  |  |
| 2  | X Air-cooled Water-cooled   | Type:        | Screw                   |  |  |  |  |
|  |   | # of Stages: | 1                       |  |  |  |  |
| 3*   | Rated Capacity at Full Load Operating Pressure <sup>a, e</sup>                            | 65           | acfm <sup>a,e</sup>     |  |  |  |  |
| 4*   | Full Load Operating Pressure <sup>b</sup>   | 110          | psig <sup>b</sup>       |  |  |  |  |
| 5  | Maximum Full Flow Operating Pressure  | 125          | psig <sup>c</sup>       |  |  |  |  |
| 6  | Drive Motor Nominal Rating  | 15           | hp                      |  |  |  |  |
| 7  | Drive Motor Nominal Efficiency  | 91,5         | percent                 |  |  |  |  |
| 8  | Fan Motor Nominal Rating (if applicable)  | 0,75         | hp                      |  |  |  |  |
| 9  | Fan Motor Nominal Efficiency  | 78           | percent                 |  |  |  |  |
| 0*   | Total Package Input Power at Zero Flow <sup>e</sup>                                       | 3,70         | kW <sup>e</sup>         |  |  |  |  |
| 1  | Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup> | 12,43        | $kW^d$                  |  |  |  |  |
| 2*   | Package Specific Power at Rated Capacity and Full Load Operating<br>Pressure <sup>e</sup> | 19,12        | kW/100 cfm <sup>e</sup> |  |  |  |  |
| 13   | Isentropic Efficiency   | 73,27        | Percent                 |  |  |  |  |

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217. Annex C: ACFM is actual cubic feet per minute at inlet conditions.

| CAGI<br>Compressed Air & Gas Institute | <ul> <li>ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.</li> <li>b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.</li> <li>c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.</li> <li>d. Total package input power at other than reported operating points will vary with control strategy.</li> <li>e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:</li> <li><u>NOTE: The terms "power" and "energy" are synonymous for purposes of this document.</u></li> </ul> |   |                  |                                |                              |  |  |
|--|--|---|------------------|--------------------------------|------------------------------|--|--|
|  |  | Volume Flow Rate<br>at specified conditions | Volume Flow Rate | Specific Energy<br>Consumption | No Load / Zero Flow<br>Power |  |  |
| Member                                 | $\underline{m^3 / \min}$   | <u>ft<sup>3</sup> / min</u>                 | %                | %                              | %                            |  |  |
|  | Below 0.5  | Below 17.6                                  | +/- 7            | +/- 8                          |                              |  |  |
|  | 0.5 to 1.5   | 17.6 to 53                                  | +/- 6            | +/- 7                          | +/- 10%                      |  |  |
|  | 1.5 to 15  | 53 to 529.7                                 | +/- 5            | +/- 6                          | +/- 10%                      |  |  |
| ROT 030.1                              | Above 15   | Above 529.7                                 | +/- 4            | +/- 5                          |                              |  |  |

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.