## COMPRESSOR DATA SHEET

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Fixed Speed**

MODEL DATA - FOR COMPRESSED AIR					
1	Manufacturer: BOGE Compressor				
	Model Number: S 271-3 N	Date:	25.03.2021		
2	X Air-cooled Water-cooled	Type:	Screw		
		# of Stages:	1		
3*	Rated Capacity at Full Load Operating Pressure a, e	1260	acfm <sup>a,e</sup>		
4*	Full Load Operating Pressure <sup>b</sup>	100	psig		
5	Maximum Full Flow Operating Pressure c	100	psig <sup>c</sup>		
6	Drive Motor Nominal Rating	268	hp		
7	Drive Motor Nominal Efficiency	96,5	percent		
8	Fan Motor Nominal Rating (if applicable)	10	hp		
9	Fan Motor Nominal Efficiency	91,5	percent		
10*	Total Package Input Power at Zero Flow	59,1	kW <sup>e</sup>		
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	236,80	$kW^d$		
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure e	18,79	kW/100 cfm <sup>e</sup>		
13	Isentropic Efficiency	70,71	Percent		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

- a. Measured at the discharge terminal point of the compressor package in accordance with
- ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.

  b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.

  d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

Member

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.						
	Volume Flow Rate at specified conditions		Specific Energy Consumption	No Load / Zero Flow Power		
$\underline{\mathbf{m}^3 / \mathbf{min}}$	$\underline{\text{ft}^3} / \underline{\text{min}}$	%	%	%		
Below 0.5	Below 17.6	+/- 7	+/- 8			
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	. / 100/		
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%		
Above 15	Above 529.7	+/- 4	+/- 5			

ROT 030.1

12/19 Rev This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data