COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

				OR COMPRESSEI			
1	Manufacturer:	BOGE					
	Model Number: C 7 PM N					28.03.2024	
2	X Air-cooled Water-cooled				Type:	Screw	
					# of Stages:	1	
3*	Full Load Oper	rating Pressu	re	125	psig		
4	Drive Motor N	ominal Ratir	ng	7,5	hp		
5	Drive Motor N	Drive Motor Nominal Efficiency			percent		
6	Fan Motor Nor	Fan Motor Nominal Rating (if applicable)			hp		
7	Fan Motor Nor	ninal Efficie	ncy	26,2	percent		
	Input Power (kW)			Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d		
	6,5			31,3	20,75		
8*	5,7			25,2	22,44		
	5,0			21,7	22,83		
	4,3			17,9	23,80		
	3,0			10,5	28,94		
9*	Total Package	Total Package Input Power at Zero Flow c, d			kW		
10	Isentropic Effic	Isentropic Efficiency					
11	Note: Graph is only a vis Note: Y-Axis Scale, 10 to 35, 4			25,0 Capacity (ACFM) sual representation of the data in + 5kW/100acfm increments if nece 0 to 25% over maximum capacity		50,0	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	lume Flow Rate ecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\frac{1}{\text{m}^3 / \text{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.