## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

## **Rotary Compressor: Variable Frequency Drive**

1	Manufacturer:	BOGE					
	Model Number	:: S 160-4 LF N		Date:	21.07.2022		
2	X Air-co	ooled Water-cool	ed	Туре:	Screw		
				# of Stages:	1		
3*	Full Load Oper	rating Pressure <sup>b</sup>	100	n of Suges.	psig		
4	Drive Motor N		200		hp		
5	Drive Motor N	ominal Efficiency	96,5	percent			
6	Fan Motor Nor	ninal Rating (if applicab	le) 7,0	hp			
7	Fan Motor Nor	ninal Efficiency	91,7		percent		
8*	Input Power	r (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>			
		183,0	1013,3	18,06			
		147,8	838,7	17,62			
		98,0	575,9	17,02			
	-	75,9	432,1	17,56			
		42,1	193,4	21,78			
9*	Total Package	Input Power at Zero Flow	w <sup>c, d</sup> 0,0		kW		
10	Isentropic Effic	ciency	75,8%	%			
	Specific Power (kW/100 ACFM)	35,00 30,00 25,00					
11		20,00					
		Note: Graph i Note: Y-Axis Scale	750075507500750750575057505750675506755	in Section 8 cessary above 35	19 <b>2559,1F000,065,00</b> ,75,0		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet. c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,

- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	$\underline{\text{ft}^3} / \underline{\text{min}}$	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.