## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

## **Rotary Compressor: Variable Frequency Drive**

1	Manufaaturar	BOGE		OR COMPRESSE	DAIK	
1	Manufacturer:					
	Model Number	: S 160-4 I	LF N		Date:	21.07.2022
2	X Air-cooled Water-cooled				Type:	Screw
					# of Stages:	1
3*	Full Load Operating Pressure <sup>b</sup>			110	psig <sup>b</sup>	
4	Drive Motor Nominal Rating			200	hp	
5	Drive Motor Nominal Efficiency			96,5	percent	
6	Fan Motor Nominal Rating (if applicable)			7,0	hp	
7	Fan Motor Nor	Fan Motor Nominal Efficiency			percent	
	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>	
	180,8			992,2	18,22	
8*	152,2			838,2	18,16	
	101,1			573,8	17,62	
	78,2			430,6	18,17	
	43,3			192,4	22,49	
9*	Total Package Input Power at Zero Flow c, d			0,0	kW	
10	Isentropic Efficiency			77,7%	%	
	Specific Power (KW/100 ACFM)	35,00 30,00 25,00 20,00				
11	15,00 10,00 0,25,50,05100,01,50,05202,052,03,05,03,05 Note: Graph is only a			Q.03,04,05,04,05,05,05,05,06,06,05,96,07 Capacity (ACFM) isual representation of the data in + 5kW/100acfm increments if nece	Section 8	7500925589.75000.8550.0

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet. c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,

- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	ume Flow Rate ecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power	
$\underline{m}^3 / \underline{min}$	$\underline{\text{ft}^3} / \underline{\text{min}}$	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8		
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%	
1.5 to 15	53 to 529.7	+/- 5	+/- 6		
Above 15	Above 529.7	+/- 4	+/- 5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.