COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Fixed Speed MODEL DATA - FOR COMPRESSED AIR Manufacturer: 1 **BOGE Compressor** S 341-3 N Model Number: Date: 25.03.2021 2 X Air-cooled Water-cooled Type: Screw # of Stages: 1 Rated Capacity at Full Load Operating Pressure a, e acfm^{a,e} 3* 1427 b psig Full Load Operating Pressure b 4* 115 Maximum Full Flow Operating Pressure psig^c 5 125 Drive Motor Nominal Rating 6 335 hp Drive Motor Nominal Efficiency 7 96,5 percent Fan Motor Nominal Rating (if applicable) 8 15 hp Fan Motor Nominal Efficiency 9 92,2 percent Total Package Input Power at Zero Flow^e kW^e 70,9 10* Total Package Input Power at Rated Capacity and Full Load $kW^{d} \\$ 283,80 11 Operating Pressure^d Package Specific Power at Rated Capacity and Full Load Operating 12* 19,89 kW/100 cfm^e Pressure Isentropic Efficiency 13 72,19 Percent *For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator.

Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

- a. Measured at the discharge terminal point of the compressor package in accordance with

e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

- ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.
 b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the
- maximum pressure attainable before capacity control begins. May require additional power. d. Total package input power at other than reported operating points will vary with control strategy.



NOTES:

mpressed Air & Gas Institute 🔎	NOTE: The terms "po	ower" and "energy" are synonymous for purposes of this	document.		
		Volume Flow Rate at specified conditions		Specific Energy Consumption	No Load / Zero Fl Power
Member	$\underline{m^3 / \min}$	<u>ft³ / min</u>	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
Г 030.1	Above 15	Above 529.7	+/- 4	+/- 5	

Flow

ROT 030.1

12/19 Rev 1 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data