COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

				OR COMPRESSE		
1	Manufacturer:	BOGE	E			
	Model Number	r: C 14 F	PM N		Date:	28.03.2024
2	x Air-cooled Water-cooled				Type:	Screw
					# of Stages:	1
3*	Full Load Operating Pressure ^b			100	in of stages.	psig ^b
4	Drive Motor N	Drive Motor Nominal Rating			hp	
5	Drive Motor Nominal Efficiency			92,2	percent	
6	Fan Motor Nominal Rating (if applicable)			0,5	hp	
7	Fan Motor Nominal Efficiency			26,2	percent	
8*	Input Power (kW)			Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	12,5			61,4		,36
	8,0			39,2	20,41	
	6,6			32,2	20,47	
		3,9			21,43	
	2,7			11,0	24	,66
9*	Total Package Input Power at Zero Flow c, d			0,0		kW
10	Isentropic Efficiency			65,1%	%	
11	Specific Power (kW/100 ACFM)	35,00 30,00 25,00 20,00 15,00 10,00 0,0	25,0		50,0	75,0
		N	Note: Graph is only a visote: Y-Axis Scale, 10 to 35,	Capacity (ACFM) sual representation of the data is + 5kW/100acfm increments if nec 0 to 25% over maximum capacity		

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}}^3 / \underline{\mathbf{min}}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.