COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR

	Model Number	: S 132-4 LF N		Date:	22.07.2022
2	X Air-co	oled Water-cooled	l	Type: Screw	
				# of Stages:	1
*	Full Load Oper	rating Pressure ^b	110	psig ^b	
ļ	Drive Motor No	ominal Rating	175	hp	
5	Drive Motor No	ominal Efficiency	96,5	percent	
5	Fan Motor Non	ninal Rating (if applicable)) 4,0	hp	
7	Fan Motor Non	Fan Motor Nominal Efficiency		percent	
8*	Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
		153,4	884,1	17,	
	124,1		728,7	17,03	
	75,8		443,3	17,10	
	52,4		285,6	18,35	
	39,6		192,4	20,59	
*	Total Package Input Power at Zero Flow ^{c, d}		^{c, d} 0,0	kW	
0	Isentropic Efficiency		81,4%	%	
		35,00			
	Le	30,00			
	Specific Power (kW/100 ACFM)	25,00			
1	(KW)	20,00			
		15,00			

Capacity (ACFM)

Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator

Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	$\underline{\mathrm{ft}^3} / \mathrm{min}$	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.