	Rotary Compressor: Fixed Speed						
MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: BOGE Compressor						
	Model Number: S 111-4 N	Date:	21.07.2022				
2	X Air-cooled Water-cooled	Type:	Screw				
		# of Stages:	1				
3*	Rated Capacity at Full Load Operating Pressure ^{a, e}	766	acfm ^{a,e}				
4*	Full Load Operating Pressure ^b	100	psig				
5	Maximum Full Flow Operating Pressure ^c	100	psig ^c				
6	Drive Motor Nominal Rating	150	hp				
7	Drive Motor Nominal Efficiency	96,2	percent				
8	Fan Motor Nominal Rating (if applicable)	4	hp				
9	Fan Motor Nominal Efficiency	89,5	percent				
10*	Total Package Input Power at Zero Flow ^e	22,4	kW ^e				
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	125,62	kW^d				
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e	16,39	kW/100 cfm ^e				
13	Isentropic Efficiency	81,06	Percent				

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

NOTES:	 ISO 1217, Annex C; A0 b. The operating pressure a for this data sheet. c. Maximum pressure attain maximum pressure attain d. Total package input powe. Tolerance is specified in 	ge terminal point of the compressor package in CFM is actual cubic feet per minute at inlet conc at which the Capacity (Item 3) and Electrical Co inable at full flow, usually the unload pressure s inable before capacity control begins. May requ wer at other than reported operating points will we in ISO 1217, Annex C, as shown in table below: wer" and "energy" are synonymous for purposes	itions. nsumption (Item 11) were measured etting for load/no load control or the ire additional power. ary with control strategy.		
		Volume Flow Rate at specified conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
Member	$\underline{m^3 / \min}$	<u>ft³ / min</u>	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	- (100/
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
ROT 030.1	Above 15	Above 529.7	+/- 4	+/- 5	

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported