COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR								
1 Man	ufacturer:	BOGE						
Mod	Model Number: C 9 PM N			Date:	28.03.2024			
2 x	Air-co	oled Water-cooled		Type:	Screw			
				# of Stages:	1			
3* Full	Load Oper	ating Pressure ^b	100		psig			
4 Driv	e Motor No	ominal Rating	10	hp				
5 Driv	e Motor No	ominal Efficiency	92,2	percent				
6 Fan I	Motor Non	ninal Rating (if applicable)	0,5	hp				
7 Fan I	Motor Non	ninal Efficiency	26,2	percent				
I	nput Powe	r (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d				
		9,4	48,0	19,58				
8*		6,7	32,2	20,81				
		5,4	25,2	21,43				
		4,0	18,2	22,22				
		2,8	11,0	25,	39			
9* Tota	l Package l	Input Power at Zero Flow c, d	0,0	kW				
10 Isent	tropic Effic	iency	64,2%					
11	Specific Power (kW/100 ACFM)	Note: Graph is only a	25,0 50 Capacity (ACFM) visual representation of the data in 5, + 5kW/100acfm increments if necessary		75,0			

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.