## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

**Rotary Compressor: Variable Frequency Drive** 

MODEL DATA - FOR COMPRESSED AIR									
1	Manufacturer:	BOGE	E						
	Model Number: C 9 PM N				Date:	28.03.2024			
2	X Air-cooled Water-cooled				Type:	Screw			
				#	of Stages:	1			
3*	Full Load Operating Pressure <sup>b</sup>			150	psig				
4	Drive Motor Nominal Rating			10	hp				
5	Drive Motor Nominal Efficiency			92,2	percent				
6	Fan Motor Nominal Rating (if applicable)			0,5	hp				
7	Fan Motor Nominal Efficiency			26,2	percent				
	Input Power (kW)			Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	10,2			43,4	23,49				
8*	8,0			31,8	25,28				
	6,5		24,8	26,01					
	4,9		17,5	28,11					
	3,5		10,2	34,12					
9*	Total Package Input Power at Zero Flow c, u			0,0	kW				
10	Isentropic Efficiency			64,9%					
11	Specific Power (kW/100 ACFM)	35,00 30,00 25,00 20,00 15,00 10,00 0,0	Note: Graph is only a vis	25,0 Capacity (ACFM) rual representation of the data in 3 5 5kW/100acfm increments if neces 0 to 25% over maximum capacity		50,0			

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{\mathbf{m}^3 / \mathbf{min}}$	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.