COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR										
1	Manufacturer:	BOG	E							
	Model Numbe	er: C18-2	LFN		Date:	09.11.21				
2	X Air-co	ooled	Water-cooled		Type:	Screw				
					# of Stages:	1				
3*	Full Load Ope	Full Load Operating Pressure			psig					
4	Drive Motor N	Drive Motor Nominal Rating			hp					
5	Drive Motor Nominal Efficiency			93,0	percent					
6	Fan Motor No	Fan Motor Nominal Rating (if applicable)			hp					
7	Fan Motor No	Fan Motor Nominal Efficiency			percent					
8*	Input Power (kW)			Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	23,0			112	20,54					
	15,3			78	19,62					
	12,2	12,2		61	20,00					
	9,6			44	21,82					
	5,8			19	30,53					
9*	Total Package	Total Package Input Power at Zero Flow c, d				kW				
10	Isentropic Effi	Isentropic Efficiency			%					
11	Sentropic Efficiency 68,9% %									

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	olume Flow Rate pecified conditions	Volume Flow Rate	Specific Energy Consumption	Zero Flow Power
$\underline{m}^3 / \underline{min}$	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data