COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Fixed Speed

1	Manufacturer: BOGE Compressor		
2	Model Number: C 22-2 N	Date:	27.04.2021
	X Air-cooled Water-cooled	Type:	Screw
		# of Stages:	1
3*	Rated Capacity at Full Load Operating Pressure a, e	135	acfm ^{a,e}
1*	Full Load Operating Pressure ^b	100	psig ^b
5	Maximum Full Flow Operating Pressure ^c	100	psig ^c
6	Drive Motor Nominal Rating	30	hp
7	Drive Motor Nominal Efficiency	92	percent
8	Fan Motor Nominal Rating (if applicable)	0,75	hp
9	Fan Motor Nominal Efficiency	78	percent
10*	Total Package Input Power at Zero Flow ^e	7,60	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	25,55	kW^d
12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure ^e	18,93	kW/100 cfm ^e
13	Isentropic Efficiency	70,22	Percent
	els that are tested in the CAGI Performance Verification Program, these items are v	5 X 5	ministrator.
Sult C	 CAGI website for a list of participants in the third party verification program: a. Measured at the discharge terminal point of the compressor package in accordation ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity (Item 3) and Electrical Consump for this data sheet. c. Maximum pressure attainable at full flow, usually the unload pressure setting f maximum pressure attainable before capacity control begins. May require add 	tion (Item 11) were measured or load/no load control or the	



d. Total package input power at other than reported operating points will vary with control strategy.
 e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

Compressed Air & Gas Institute	NOTE: The terms "power" and "energy" are synonymous for purposes of this Volume Flow Rate at specified conditions		document. Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
Member	$\underline{m^3 / min}$	<u>ft³ / min</u>	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	-7- 10%
ROT 030.1	Above 15	Above 529.7	+/- 4	+/- 5	
	-				

12/19 Rev . This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.